

District Laboratory
Drinking Water & Sanitation Division,
Pakur

Collect Sample Source :- *Tube well*

Date:- *03/03/2021*

Water Test Report

Location :- *D.P.S. PAKUR*

Sl.No.	TDS	Alkalinity	PH	Hardness
Requirment Acceptable Limit	500 mg/l	200 mg/l	6.5	200 mg/l
Permissible Limit in the absence of alternate source	200 mg/l	600 mg/l	8.5	600 mg/l
Result	<i>140 mg/l</i>	<i>60 mg/l</i>	<i>7.3</i>	<i>90 mg/l</i>

Signature
03/03/2021
Signature Chemist
D. W & S. Division, Pakur

R. Banerjee
03/03/2021
District Coordinator
D. W & S. Division, Pakur

Signature
03/03/2021
Executive Engineer
D. W & S. Division, Pakur

Arunanda
Manager
Delhi Public School, Pakur

B. Mohanty
Principal
Delhi Public School Pakur
Affiliated to C.B.S.E
Affn. No.-3430354